




PLAN VIEW
(SCALE: 2X)



LEFT SIDE VIEW



FRONT VIEW

TANK DIMENSION REFERENCE CHART (SHOWN IN INCHES)

TANK RATED CAPACITY	A - HEIGHT (TANK)	D - DEPTH * (OVERALL)	E - MTG HOLES (CTR-TO-CTR)	F - DEPTH * (INNER TANK)	U/L VENT NPT SIZE
50 GAL.	33.50	21.00	19.50	18.00	2.00
60 GAL.	41.50	21.00	19.50	18.00	3.00
75 GAL.	46.50	21.00	19.50	18.00	3.00
100 GAL.	46.50	27.00	25.50	24.00	3.00
150 GAL.	46.50	39.00	37.50	36.00	3.00

* Depth dimension - Front-to-Back

REF#	DESCRIPTION OF STANDARD EQUIPMENT
1	CONTROL PANEL
2	6-1/2" X 6-1/2" INSPECTION PLATE
3	6" x 6" MOTOR MOUNTING PLATE
4	1-1/2" NPT - FUEL LEVEL GAUGE
5	FUEL INLET/OUTLET TO/FROM TANK w /DROP TUBES
6	2" x 1" NPT - ENGINE FUEL SUPPLY w /DROP TUBE
7	2" x 1" NPT - ENGINE FUEL RETURN w /DROP TUBE
8	2" NPT - TANK VENT TO ATMOSPHERE
9	1" NPT - DROP TUBES for ENGINE SUPPLY & RETURN
10	1" NPT - OVERFLOW TO MAIN STORAGE TANK
11	1/2" NPT - TANK DRAIN (PLUGGED)
12	2" NPT - EXTRA CONNECTION
13	2" NPT - MANUAL FILL w /DROP TUBE
ADDITIONAL EQUIPMENT IF TANK IS U/L LISTED	
40	NPT CONNECTION FOR U/L EMERGENCY RELIEF VENT (See Above Chart For Size)

CONSTRUCTION NOTES	
1	TANK TOP, BOTTOM, & SHELL - 12 GAUGE STEEL
2	DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE

MANUAL SINGLE WALL DAY TANK
PY50M - PY150M
PY50MUL - PY150MUL (U/L Listed Version)



DRAWN BY: RES	DATE: 03/01/2008
CHECKED BY: DJW	REV: 03/01/2008
SHEET NO. 1 of 1	DWG #: MAN_SW_B