



REF#	DESCRIPTION OF STANDARD EQUIPMENT
1	CONTROL PANEL
2	6-1/2" X 6-1/2" INSPECTION PLATE
3	REMOVABLE COVER
4	1-1/2" NPT - FUEL LEVEL GAUGE
5	FUEL INLET/OUTLET TO/FROM TANK
6	2" x 1" NPT - ENGINE FUEL SUPPLY w/DROP TUBE
7	2" x 1" NPT - ENGINE FUEL RETURN w/DROP TUBE
8	2" NPT - TANK VENT TO ATMOSPHERE
9	1" NPT - DROP TUBES for ENGINE SUPPLY & RETURN
10	1" NPT - OVERFLOW TO MAIN STORAGE TANK
11	1/2" NPT - TANK DRAIN w/DROP TUBE (PLUGGED)
ADDITIONAL EQUIPMENT IF TANK IS U/L LISTED	
40	2" NPT CONNECTION FOR U/L EMERGENCY RELIEF VENT

CONSTRUCTION NOTES	
1	TANK TOP, BOTTOM, & SHELL - 12 GAUGE STEEL
2	DIMENSIONS SUBJECT TO CHANGE WITHOUT NOTICE

**TRIM SINGLE WALL DAY TANK**  
PY10T  
PY10TUL (U/L Listed Version)



**PRYCO, INC.**

MECHANICSBURG, ILLINOIS

DRAWN BY: <i>RES</i>	DATE: 03/01/2008
CHECKED BY: <i>DW</i>	REV: 03/01/2008
SHEET NO. 1 of 1	DWG #: TRM_SW_A